

i-352 comment

Items 5 and 6 of attachment

The table 3 values, in Clause 6.1.3 "DGA status norms" on pages 36-37, represent changes of gas ppm values for indeterminate values of sample time intervals. Values used for short time intervals give high rates and the same values used for long time intervals give much lower rates.

1-352 suggested revision

I propose the following to change my negative vote: Remove Table 3.

i-352 disposition rejected

As explained on page 32, Table 3 is in integral part of the DGA analysis process described in the guide. Also paragraph 3 of 6.1.4 give an explanation of Table 3 and 4: "However, the work performed in the analysis of the DGA results indicated that obtaining a meaningful evaluation of the gassing rates requires more than the common practice of using two consecutive DGA to compute a yearly rate. Instead, this guide uses two different tables (Table 3 (delta without normalization) and Table 4 (multi point rates)) to evaluate the gassing tendency of a DGA set to overcome the effect of normal random fluctuations of the DGA process. See B.1 for a more detailed explanation of the why and how of this process."

Draft Minutes

Pages 1-4 of this document.



